

Certificate of constancy of performance for product

0679-CPR-0196

(English translation, the original version is in French)

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 march 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, it has been stated that the construction products indicated in the following page, placed on the European economic area market by :

AGENCE POUR LA RENOVATION DES SOLS

2 bis avenue François Sommer
BP 60065 Glaire
08206 SEDAN CEDEX
FRANCE

and produced in the factory:

AGENCE POUR LA RENOVATION DES SOLS 2 bis avenue François Sommer - BP 60065 Glaire 08206 SEDAN CEDEX - FRANCE

are submitted by the manufacturer to a factory production control and to the further testing of samples taken of the factory in accordance with a prescribed test plan and that the notified body - CSTB - has performed the assessment of performance of fire reaction of construction products, the initial inspection of the manufacturing plant and of the factory production control and performs the continuous surveillance, assessment and evaluation of the factory production control (system 1).

This certificate attests to the products performance of fire reaction and that all provisions concerning the assessment and verification of constancy of performance described in the harmonized reference technical specification:

EN 14041 : 2004

Are applied and that the products fulfill all the prescribed requirements.

Products fire reaction performance: B_f - s1, valid when maintained with a bonding system to any A2_f - s1 or A1_f rated substrate whose density is $\geq 1200 \text{ kg/m}^3$.

This certificate can only be used in conjunction with the declaration of performance of the products written by the manufacturer or his authorised representative established in the European economic area and with the technical specification in reference.


This certificate is issued on 9th of February 2018, it cancels and replaces the certificate previously delivered on 10th of December 2015 and, except for withdrawal or suspension, remains valid as long as the conditions laid down in the corresponding technical specification in reference or the manufacturing conditions in the factory or the factory production control itself are not modified significantly.

This certificate comprises 2 pages.

The list of certificates issued by CSTB is kept up-to-date by the CSTB.

Issued in Champs sur Marne, on 9th of February 2018

For CSTB
On behalf of the Technical Director


Yannick LEMOIGNE

Products

TECSOM 2050 PREMIUM / 2050 PREMIUM DESIGN
TECSOM 2500 Nordic
TECSOM 2520 VARIATIONS
TECSOM 3550 LINEAR VISION
TECSOM 3580 CITY SQUARE
TECSOM 3600 Green System
TECSOM 3620 POINTE
TECSOM 3630S SUPREME / LINEAR FEVER II
TECSOM 3680 EXCELLENCE
TECSOM 3700 CONFIDENCE
TECSOM 3710 LIGNE TS / LINEAR SPIRIT II
TECSOM 3710 LIGNE / LINEAR SPIRIT
TECSOM 3800 CROSS
TECSOM CAMERA
TECSOM DECO 700
TECSOM DECOSTRUCTURE LOOP
TECSOM OMBRE
TECSOM NUANCE
TECSOM SENSUAL CITY
TECSOM DECOSTRUCTURE TIP-SHEARED
TECSOM REFLET
TECSOM PRIMA
TEXTIDALLE 40
TECSOM EVOLUTION
TECSOM LVM

Product type :

Tufted textile floor covering in tiles with 100% PA loop pile on PVC backing.

Use category :

Internal use as floor covering